



www.safti.com | 888.653.3333

2015 IBC 716 TABLES

716.3 Marking Fire Rated Glazing Assemblies

716.5 Opening Fire Protection Assemblies, Ratings and Markings

716.6 Fire Window Assembly Fire Protection Ratings

The SAFTI FIRST recommended product found in these tables are not part of the 2015 IBC, but provided by SAFTI FIRST as guide for choosing and specifying the correct code approved product. If you have any questions regarding these tables, contact SAFTI FIRST at 888.653.3333 or send an email to info@safti.com.

2015 IBC Table 716.3

Marking Fire-Rated Glazing Assemblies

Fire Test Standard	Marking	Definition of Marking	Recommended SAFTI FIRST Product (not in IBC – added for easy reference)
ASTM E119 or UL 263	W	Meets wall assembly criteria.	SuperLite II-XL 60-120 SuperLite II-XLB 60-120 (oversized/butt-glazed) SuperLite II-XLM 60-120 (butt-glazed)
NFPA 257 or UL 9	OH	Meets fire window assembly criteria including the hose stream test.	SuperClear 45-HS/SuperClear 45-HS-LI SuperLite II-XL 45 SuperLite I-W PYRAN Platinum by SAFTI FIRST PYRAN Platinum F by SAFTI FIRST PYRAN Platinum L by SAFTI FIRST
NFPA 252 or UL 10B or UL 10C	D	Meets fire door assembly criteria.	SuperLite I SuperClear 45-HS/SuperClear 45-HS-LI SuperLite II-XL 45-90 SuperLite I-W SuperLite X-45/60/90 PYRAN Platinum F by SAFTI FIRST PYRAN Platinum L by SAFTI FIRST
	H	Meets fire door assembly “Hose Stream” test.	SuperClear 45-HS/SuperClear 45-HS-LI SuperLite II-XL 45-120 SuperLite I-W SuperLite X-45/60/90 PYRAN Platinum F by SAFTI FIRST PYRAN Platinum L by SAFTI FIRST
	T	Meets 450° F temperature rise criteria for 30 minutes	SuperLite II-XL 45-120
	XXX	The time in minutes of the fire resistance or fire protection rating of the glazing assembly	

For SI: °C = [(°F) – 32]/1.8.

2015 IBC Table 716.5

Opening Fire Protection Assemblies, Ratings and Markings

TYPE OF ASSEMBLY	REQUIRED WALL ASSEMBLY RATING (HRS.)	MINIMUM FIRE DOOR AND FIRE SHUTTER ASSEMBLY RATING (HRS.)	DOOR VISION PANEL SIZE ^b	FIRE RATED GLAZING MARKING DOOR VISION PANEL ^d	Recommended SAFTI FIRST Product for Door Vision Panel (not in IBC – added for easy reference)	MINIMUM SIDELITE/TRANSOM ASSEMBLY RATING (HRS.)		FIRE RATED GLAZING MARKING SIDELITE/TRANSOM PANEL		Recommended SAFTI FIRST Product for Sidelite/Transom (not in IBC – added for easy reference)
						Fire Protection	Fire Resistance	Fire Protection	Fire Resistance	
Fire walls and fire barriers having a required fire resistance rating greater than 1 hour	4	3	See Note b	D-H-W-240		Not Permitted	4	Not Permitted	W-240	
	3	3 ^a	See Note b	D-H-W-180		Not Permitted	3	Not Permitted	W-180	
	2	1-1/2	100 sq. in.	≤100 sq. in. = D-H-90 >100 sq. in. =D-H-T-W-90	SuperLite X-45/60/90 SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST SuperLite II-XL 90	Not Permitted	2	Not Permitted	W-120	SuperLite II-XL 120 SuperLite II-XLB 120 (oversized/butt-glazed) SuperLite II-XLM 120 (butt-glazed)
	1-1/2	1-1/2	100 sq. in.	≤100 sq. in. = D-H-90 >100 sq. in. =D-H-T-W-90	SuperLite X-45/60/90 SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST SuperLite II-XL 90	Not Permitted	1-1/2	Not Permitted	W-90	SuperLite II-XL 90
Enclosures for shafts, interior exit stairways and interior exit ramps	2	1-1/2	100 sq. in.	≤100 sq. in. = D-H-90 >100 sq. in. =D-H-T-W-90	SuperLite X-45/60/90 SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST SuperLite II-XL 90	Not Permitted	2	Not Permitted	W-120	SuperLite II-XL 120 SuperLite II-XLB 120 (oversized/butt-glazed) SuperLite II-XLM 120 (butt-glazed)
Horizontal exits in fire walls ^e	4	3	100 sq. in.	≤100 sq. in. = D-H-180 >100 sq. in. D-H-W-240	PYRAN Platinum F and L by SAFTI FIRST	Not Permitted	4	Not Permitted	W-240	
	3	3 ^a	100 sq. in.	≤100 sq. in. = D-H-180 >100 sq. in. D-H-W-180	PYRAN Platinum F and L by SAFTI FIRST	Not Permitted	3	Not Permitted	W-180	

(continued on next page)

TYPE OF ASSEMBLY	REQUIRED WALL ASSEMBLY RATING (HRS.)	MINIMUM FIRE DOOR AND FIRE SHUTTER ASSEMBLY RATING (HRS.)	DOOR VISION PANEL SIZE ^b	FIRE RATED GLAZING MARKING DOOR VISION PANEL ^d	Recommended SAFTI FIRST Product for Door Vision Panel (not in IBC – added for easy reference)	MINIMUM SIDELITE/TRANSOM ASSEMBLY RATING (HRS.)		FIRE RATED GLAZING MARKING SIDELITE/TRANSOM PANEL		Recommended SAFTI FIRST Product for Sidelite/Transom (not in IBC – added for easy reference)
						Fire Protection	Fire Resistance	Fire Protection	Fire Resistance	
Fire barriers having a required fire-resistance rating of 1 hour: Enclosures for shafts, exit access stairways, exit access ramp, interior exit stairways, interior exit ramps and exit passageway walls.	1	1	100 sq. in ^c	≤100 sq. in. = D-H-60 >100 sq. in. = D-H-T-60 or D-H-T-W-60	SuperLite I-W SuperLite X-45/60/90 PYRAN Platinum F and L by SAFTI FIRST SuperLite II-XL 60	Not Permitted	1	Not Permitted	W-60	SuperLite II-XL 60 SuperLite II-XLB 60 (oversized/butt-glazed) SuperLite II-XLM 60 (butt-glazed)
						Fire Protection				
Other Fire Barriers	1	3/4	Maximum Size Tested	D-H-45	SuperClear 45-HS/HS-LI SuperLite II-XL 45 SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST	3/4		D-OH-45		SuperClear 45-HS/HS-LI SuperLite II-XL 45 SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST
Fire Partitions / Corridor Walls	1	1/3 ^b	Maximum Size Tested	D-20	SuperLite I & I-XL SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST	3/4 ^b		D-OH-45		SuperClear 45-HS/HS-LI SuperLite II-XL 45 SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST
	0.5	1/3 ^b	Maximum Size Tested	D-20	SuperLite I & I-XL SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST	1/3		D-OH-20		SuperClear 45-HS/HS-LI SuperLite II-XL 45 SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST
Other Fire Partitions	1	3/4	Maximum Size Tested	D-H-45	SuperClear 45-HS/HS-LI SuperLite II-XL 45 SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST	3/4		D-OH-45		SuperClear 45-HS/HS-LI SuperLite II-XL 45 SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST
	0.5	1/3	Maximum Size Tested	D-20	SuperLite I & I-XL SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST	1/3		D-OH-20		SuperClear 45-HS/HS-LI SuperLite II-XL 45 SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST

(continued on next page)

TYPE OF ASSEMBLY	REQUIRED WALL ASSEMBLY RATING (HRS.)	MINIMUM FIRE DOOR AND FIRE SHUTTER ASSEMBLY RATING (HRS.)	DOOR VISION PANEL SIZE ^b	FIRE RATED GLAZING MARKING DOOR VISION PANEL ^d	Recommended SAFTI FIRST Product for Door Vision Panel (not in IBC – added for easy reference)	MINIMUM SIDELITE/TRANSOM ASSEMBLY RATING (HRS.)		FIRE RATED GLAZING MARKING SIDELITE/TRANSOM PANEL		Recommended SAFTI FIRST Product for Sidelite/Transom (not in IBC – added for easy reference)	
						Fire Protection	Fire Resistance	Fire Protection	Fire Resistance		
Exterior Walls	3	1-1/2	100 sq. in. ^b	≤100 sq. in. = D-H-90 >100 sq. in. =D-H-T-W-90	SuperLite X-45/60/90 SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST SuperLite II-XL 90	Not Permitted	3	Not Permitted	W-180		
	2	1-1/2	100 sq. in. ^b	≤100 sq. in. = D-H-90 >100 sq. in. =D-H-T-W-90	SuperLite X-45/60/90 SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST SuperLite II-XL 90	Not Permitted	2	Not Permitted	W-120	SuperLite II-XL 120 SuperLite II-XLB 120 (oversized/butt-glazed)	
							Fire Protection				
	1	3/4	Maximum Size Tested	D-H-45	SuperClear 45-HS/HS-LI SuperLite II-XL 45 SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST	3/4		D-H-45		SuperClear 45-HS/HS-LI SuperLite II-XL 45 SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST	
Smoke Barriers							Fire Protection				
	1	1/3	Maximum Size Tested	D-20	SuperLite I & I-XL SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST	3/4		D-OH-45		SuperClear 45-HS/HS-LI SuperLite II-XL 45 SuperLite I-W PYRAN Platinum F and L by SAFTI FIRST	

For SI: 1 square inch – 645.2 mm

- Two doors, each with a fire protection rating of 1-1/2 hours, installed on opposite sides of the same opening in a fire wall, shall be deemed equivalent in fire protection rating to one 3-hour fire door.
- Fire resistance rated glazing tested to ASTM E119 in accordance with Section 716.2 shall be permitted, in the maximum size tested.
- Except where the building is equipped throughout with an automatic sprinkler and the fire-rated glazing meets the criteria established in Section 716.5.5.
- Under the column heading "Fire rated glazing marking door vision panel", W refers to the fire-resistance rating of the glazing, not the frame.
- See Section 716.5.8.1.2.1.

2015 IBC Table 716.6

Fire Window Assembly Fire Protection Ratings

TYPE OF WALL ASSEMBLY	REQUIRED WALL ASSEMBLY RATING (hours)	MINIMUM FIRE WINDOW ASSEMBLY RATING (hours)	FIRE RATED GLAZING MARKING	Recommended SAFTI FIRST Product (not in IBC – added for easy reference)
Interior walls				
Fire walls	All	NP ^a	W-XXX ^b	SuperLite II-XL 60-120
Fire barriers	>1	NP ^a	W-XXX ^b	SuperLite II-XLB 60-120 (oversized/butt-glazed)
	1	NP ^a	W-XXX ^b	SuperLite II-XLM 60-120 (butt-glazed)
Incidental use areas (707.3.7), Mixed occupancy separations(707.3.9)	1	¾	OH-45 or W-60	SuperLite II-XL 60 SuperLite II-XLB 60 (oversized/butt-glazed) SuperLite II-XLM 60 (butt-glazed) If less than 25% of the wall area: SuperClear 45-HS/HS-LI, SuperLite II-XL 45, , SuperLite I-W, PYRAN Platinum, PYRAN Platinum F or L by SAFTI FIRST
Fire Partitions	1 0.5	¾ 1/3	OH-45 or W-60 OH-20 or W-30	SuperLite II-XL 60 SuperLite II-XLB 60 (oversized/butt-glazed) SuperLite II-XLM 60 (butt-glazed)
Smoke Barrier	1	¾	OH-45 or W-60	If less than 25% of the wall area: SuperClear 45-HS/HS-LI, SuperLite II-XL 45, SuperLite I-W, PYRAN Platinum, PYRAN Platinum F or L by SAFTI FIRST
Exterior walls	>1	1-1/2	OH-90 or W-XXX ^b	SuperLite II-XL-120/SuperLite II-XLB Note opening limits per Table 705.8: SuperLite II-XL 90
	1	¾	OH-45 or W-60	SuperLite II-XL 60
	0.5	1/3	OH-20 or W-30	Note opening limits per Table 705.8: SuperLite II-XL 45, SuperLite I-W, PYRAN Platinum, PYRAN Platinum F or L by SAFTI FIRST
Party wall	All	NP	Not Applicable	

NP – Not Permitted

a. Not permitted except fire resistance rated glazing assemblies tested to ASTM E119 or UL 263, as specified in Section 716.2.

b. XXX = The fire rating duration period in minutes, which shall be equal to the fire resistance rating required for the wall assembly.